XVBL0G4



Main

| Range of product | Harmony XVB Universal |
|--|---|
| Product or component type | Complete beacon |
| Beacon or indicator bank unit typeBase unit with direct or tube fixing mode Illuminated unit | |
| Signalling type | Steady |
| Mounting diameter | 2.76 in (70 mm) |
| Component name | XVBL |
| Material | Glass reinforced polyamide (base unit) Polycarbonate (illuminated unit) |
| Light source | Red integral LED |
| Bulb type | Protected LED |
| [Us] rated supply voltage | 120 V AC |

Complementary

| Connections - terminals | Screw clamp terminals, connection capacity: <= 1 x 1.5 mm² with cable end |
|--|---|
| [Ui] rated insulation voltage | 250 V conforming to IEC 60947-1 |
| Nominal voltage limit | 0.851.1 Un conforming to IEC 60947-5-1 |
| Current consumption | < 17 mA AC |
| [Uimp] rated impulse withstand voltage | 4 kV conforming to IEC 60947-1 |
| CAD overall width | 2.76 in (70 mm) |
| CAD overall height | 5.47 in (139 mm) |
| CAD overall depth | 2.76 in (70 mm) |
| Terminals description ISO n°1 | (COM-1)PW (GND)GROUND |
| Product weight | 0.6 lb(US) (0.27 kg) |

Environment

| pollution degree | 2 | _ |
|-------------------------------------|--|---|
| product certifications | CCC CSA C22-2 No 14 GOST UL 508 | |
| standards | EN/IEC 60947-5-1 | _ |
| protective treatment | TC | |
| ambient air temperature for storage | -40158 °F (-4070 °C) | |
| electrical shock protection class | Class I (on support tube) conforming to IEC 61140 Class II (on base unit) conforming to IEC 61140 | |
| IP degree of protection | IP65 (on fixing base XVBZ0.) conforming to IEC 60529 IP66 (on base unit) conforming to IEC 60529 | |
| NEMA degree of protection | NEMA 4X (indoor) conforming to UL 508 | |


Offer Sustainability

| WARNING: This product can expose you to chemicals including: | WARNING: This product can expose you to chemicals including: |
|--|--|
| Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. | Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. |
| For more information go to www.p65warnings.ca.gov | For more information go to www.p65warnings.ca.gov |

Contractual warranty

Illuminated Beacon for BA 15d Bulb or LED

Dimensions



Illuminated Beacon

Wiring Diagram

